

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20240334  
Address: 3529 SE CORBIN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Kyle Beard	Failed	Friday, July 26, 2024

Corrective Action Required:

1	Miscellaneous Correction	- Final grading and sod - Provide splash pads 36" away from foundation - Sump discharge to be 36" away from foundation - Obtain irrigation permit
---	--------------------------	--

No response from letter sent 06/25/2024 to builder for TCO extension  
-Not Ready-

Corrective Action Required:

2	Miscellaneous Correction	10 day NOV letter has been issued
---	--------------------------	-----------------------------------

**Comments:**