

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20241421  
Address: 1605 SW ARBORWAY TER, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Monday, July 29, 2024

Informational:

1 Misc

Garage portal frame inspection only.

Corrective Action Required:

2 Misc

- Electrical outlets in garage incomplete/insufficient number
- Missing fire blocking at top of chase in garage
- Several
- The tension bracket at stairs leading to basement is not secured completely to stud

**Comments:**