

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20241344  
Address: 840 NW BLUE PKWY, Unit:D, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Robb Popp	Partial	Monday, July 29, 2024

Informational:  
1      Misc      OK to cover except as noted below:  
-Mechanical room (open ceiling) PVC piping must comply with sec 602 of 2018 IMC

**Comments:**