



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20110449, Building Permit - Commercial
Address: 711 SE M 291 HWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Mark Harding	Failed	Friday, September 23, 2011

Corrective Action Required
1 MISC

1. PROVIDE OPEN FRONT TOILET SEATS.
2. REMOVE DEAD BOLT LOCKS FROM EXIT DOORS
3. PROVIDE BACKFLOW ON SODA MACHINE
4. PROVIDE BACKFLOW ON ICE MACHINE
5. SUBMIT BACK FLOW TEST TO WATER DEPARTMENT.
6. MOVE TOILET PAPER CONTAINER FROM BLOCKING VERTICAL GRAB BARS IN RESTROOM.
7. PROVIDE HEALTH DEPARTMENT APPROVAL
PRYOR TO OCCUPANCY
PENDING FIRE DEPARTMENT APPROVAL

Comments: