



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRRES20113266, Building Permit - Residential  
Address: 1308 NE ERNEST WAY, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Khanh Nguyen	Failed	Friday, September 23, 2011

Corrective Action Required  
3 MISC

PROTECT NM ELECTRICAL WIRE AT GARAGE BRACE WALL CORNER; AT KITCHEN WALL NEAR SINK; INSTALL RUNNING BOARD TO PROTECT WIRING WITHIN 6FT OF ATTIC ACCESS

Corrective Action Required  
11 MISC

OVERFILLED DOUBLE GANG ELECTRICAL BOX AT STAIR BOTTOM LANDING IN BASEMENT

**Comments:**