



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

Prevention Division
(816)969-1300

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20240778	Date:	July 29, 2024
Project Title:	MCC AUTOMOTIVE INSTITUTE - BUILDING ADDITION	Applicant:	
Location:	500 SW LONGVIEW RD, LEES SUMMIT, MO 64081	SIEMENS INDUSTRY INC	
Type of Work:		P O BOX 80600	
Occupancy Group:	S-1	INDIANAPOLIS, IN 46280	
Description:	MCC AUTOMOTIVE INSTITUTE - BUILDING ADDITION AND RENOVATION OF EXISTING	Primary: (317) 596-3260	Ext: 2546
Construction Type:	Type IIB (Unprotected)		
Map Page:			

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Craig Hill

Rejected

1. Corrective Action: Exterior horn strobes are only required in courtyard spaces. Remove all exterior horn strobes except the one above the FDC.

2. Any high-volume large-diameter fans shall shutdown upon any activation of the fire alarm.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.