



**CITY OF LEE'S SUMMIT**  
**CODES ADMINISTRATION**  
220 SE GREEN ST.  
P.O. BOX 1600

**PHONE:**  
816-969-1200

**FAX:**  
816-969-1201

# Temporary Certificate of Occupancy

---

**Permit #:** PRCOM20113089  
**Address:** 930 NW BLUE PKWY, Unit:V, LEES SUMMIT, MO 64086  
**Inspected On:** Friday, September 23, 2011  
**Inspected By:** Joe Dir:John Borns  
**Expiration Date:** 9/29/2011 12:00:00 AM

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Fire</b>	Joe Dir	Passed	Friday, September 23, 2011
<b>Occupancy Inspection - Codes Commercial</b>	John Borns	Temporary C of O	Friday, September 23, 2011

**Corrective Action Required:**

1 MISC AFFIX SUITE DESIGNATION 930 V TO EACH RTU

**Corrective Action Required:**

2 MISC NEC 406.8; E3902.8: WEATHERPROOF (IN-USE) COVER REQUIRED ON ELECTRICAL RECEPTACLES AT WET LOCATIONS -- SEE AT RTU's

**Corrective Action Required:**

3 MISC PAINTING OF ROOFTOP GAS PIPING INCOMPLETE -- SEE AT EACH END

**Corrective Action Required:**

4 MISC CLEAR/CLEAN ALL DEBRIS AND UNUSED MATERIAL FROM

SUITE FOOTPRINT AT ROOFTOP

**Comments:**