

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20226232
Address: 120 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Robb Popp	Partial	Monday, July 29, 2024

Informational:

1	FIRST FLOOR	-Shaft layer, 1st and 2nd layer at 2nd floor separation in AHU 1E-233 -Shaft layer and 1st and 2nd layer at mech chase outside of AHU 1E-233
---	-------------	---

Corrective Action Required:

2	Misc	3e-322,323,264,264: -COMPLETE SCREW PATTERN AND DRYWALL INSTALLATION, SEAL PENETRATIONS
---	------	--

Corrective Action Required:

3	SECOND FLOOR
---	--------------

Corrective Action Required:

4	THIRD FLOOR	-Shaft layer at 3E-303 -Screw pattern at 3E-322, 323, 365, 264, 263
---	-------------	--

Comments: