

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242974
Address: 3022 NW THOREAU PL, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|---------------|----------|------------------------|
| Footing Inspection - Residential | Shawn Hoffman | Passed | Tuesday, July 30, 2024 |

Informational:
1 Misc - DRAINAGE IN
 - GEO GRID IN PLACE

Comments: