

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241487
Address: 3241 SW ARBOR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Residential	Mitchell Schwarz	Failed	Tuesday, July 30, 2024

Corrective Action Required:

1	Misc	Inspected 2 24"x 36" piers with 4 #4 vertical rebar in each. Plans do not specify sizing to confirm correct
---	------	--

Comments: