## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #:PRRES20240570Address:2751 SW HEARTLAND RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                           | Inspector:       | Outcome: | Date:                  |
|---------------------------------------|------------------|----------|------------------------|
| All Rough Inspection -<br>Residential | Mitchell Schwarz | Failed   | Tuesday, July 30, 2024 |
| Corrective Action Required            | :                |          |                        |
| 1 Misc                                |                  |          |                        |

-use proper size hangers for double joists above dining room, master bedroom, bed 2

Comments: