

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241488
Address: 4516 SW NAUTILUS PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pool Steel/Bonding - Residential	Shawn Hoffman	Partial	Tuesday, July 30, 2024

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">- ring bonding in place- Bonding in cover pit- Bonding wire to equipment pad- No bonding to skimmers or anode at this time- Pool cover rails not bonded
---	------	---

Ok to pour apron

Comments: