

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSITE20241662  
Address: 1200 SW LONGVIEW PARK DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Storm Sewer Construction Inspection</b>	Devon Perry	Passed	Tuesday, July 30, 2024

Informational:  
1 Misc 7-17-24 DP. SB was on site and installed the BMP. they laid fabric, large rock, the 6" pipe with holes in it, covered it with large rock and backfilled. They also installed 2 clean outs.

**Comments:**