



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRRES20113266, Building Permit - Residential
Address: 1308 NE ERNEST WAY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Monday, September 26, 2011

Corrective Action Required

1 MISC

PROTECT NM ELECTRICAL WIRE AT GARAGE BRACE WALL CORNER; AT KITCHEN WALL NEAR SINK; INSTALL RUNNING BOARD TO PROTECT WIRING WITHIN 6FT OF ATTIC ACCESS

Corrective Action Required

2 MISC

OVERFILLED DOUBLE GANG ELECTRICAL BOX AT STAIR BOTTOM LANDING IN BASEMENT

*THIS IS A 3RD INSPECTION AND ELECTRCIAN FAILED TO CORRECT THE DEFICIENCIES. WASTED TRIP FEE ACCESSED

Comments: