



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20110759, Building Permit - Commercial  
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	John Borns	Partial	Monday, September 26, 2011
Partial Correction 1 MISC		FRAMING & ABOVE-CEILING SYSTEMS @ GWB CEILINGS & SOFFITS: SOFFITS @ 00; 01; 02; 05; 23; 77;	
Partial Correction 2 MISC		CEILING FRAMING & ABOVE-CEILING SYSTEMS AT NORTH ENTRANCE CANOPY OK TO COVER WHEN READY.	
Partial Correction 3 MISC		OK TO COVER WHEN READY EYEBROW SOFFIT/FASCIA FRAMING AT OUTSIDE WALL BORDERING PATIENT ROOMS AT CORRIDORS 18, 30, & 81	
Partial Correction 4 MISC		OK TO COVER WHEN READY ACT CEILING FRAMING & ABOVE-CEILING SYSTEMS AT SPACES: 13; 15; 19; 21; 25; 27; 29; 31; 33A; 33B; 35A; 35B; 38; 40; 10; 52-69; 4; 6; 8; 9; 83; 82; 81; 30; 18; 11;	

**Comments:**