



# Masonry Inspection

**Alpha Omega Geotech, Inc**  
1701 State Avenue  
Kansas City, KS 66102  
Phone: 913-371-0000

**Client:**  
Tailor Made Exteriors  
1610 SE Hamblen Rd  
Lee's Summit, MO 64081

**Project:**  
230445  
TM Fieldhouse  
1600 SE Hamblen Rd  
Lees Summit, MO 64081

**Date:** 07/19/2024

**Inspector:** Apex Engineers

**Weather:** Sunny

**Temperature (F):** 75

## OBSERVATIONS

### **Location of Masonry Inspected:**

Masonry wall inspection at top out elevation at restroom in between grid line 6 & 7 from A to D. South masonry wall along grid line C from grid line 6 to 7 from slab to 4' 8".

**Grouted Elevation:** 0 Feet to 4 Feet

**Plans Used:** Structural Plans

**Drawing No.:** na

**Reinforcing Steel Per Contract Documents:** Yes

**Grout Placement per Contract Documents:** Yes

**Grout Temperature (F):** 50

**Discrepancy:** No

### **Remarks:**

Masonry wall inspection at top out elevation at restroom in between grid line 6 & 7 from A to D. South masonry wall along grid line C from grid line 6 to 7 from slab to 4' 8". Reinforcing steel and grout were placed per the plans and specifications. The grout was vibrated after placement. Bond beams installed per plan.