



Masonry Inspection

Alpha Omega Geotech, Inc
1701 State Avenue
Kansas City, KS 66102
Phone: 913-371-0000

Client:
Tailor Made Exteriors
1610 SE Hamblen Rd
Lee's Summit, MO 64081

Project:
230445
TM Fieldhouse
1600 SE Hamblen Rd
Lees Summit, MO 64081

Date: 07/25/2024

Inspector: Apex Engineers

Weather: Sunny

Temperature (F): 75

OBSERVATIONS

Location of Masonry Inspected: Girls East and West Restroom

Grouted Elevation: 4 Feet to 9 Feet

Plans Used: Structural Plans

Drawing No.: na

Reinforcing Steel Per Contract Documents: Yes

Grout Placement per Contract Documents: Yes

Grout Temperature (F): 50

Discrepancy: No

Remarks: Masonry wall inspection at Girls East and West Restroom (East/West interior walls from 4' 8" to 9' 4" elevation)