



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20113089, Building Permit - Commercial
Address: 930 NW BLUE PKWY, Unit:V, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Failed	Monday, September 26, 2011

Corrective Action Required
2 MISC

NEC 406.8; E3902.8: WEATHERPROOF (IN-USE) COVER
REQUIRED ON ELECTRICAL RECEPTACLES AT WET LOCATIONS
-- SEE AT RTU's

Comments: