

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20242482  
Address: 3391 NW VILLAGE PARK DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sewer Service Inspection - R</b>	Shawn Hoffman	Failed	Wednesday, July 31, 2024

Corrective Action Required:

1	Misc	- CLEANOUT REQUIRED EVERY 100' - ALL WAS COVERED AT TIME OF INSPECTION - SUPPLIED PICTURES SHOWS A NON APPROVED CONNECTION TO SEWER MAIN. ( DIG UT AND REPAIR ) - MINIMUM OF 16" OF PIPE REQUIRED BEWTEEN 45'S - MOVE CLEANOUT UPSTREAM TO REDUCE SPAN TO LESS THAN 100'
---	------	--

Comments: