

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240775
Address: 3521 SE CORBIN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Alex Fischer	Failed	Thursday, August 01, 2024

Corrective Action Required:

1	Misc	-Missing access panel/door for crawlspace beneath stairs -Address/seal hole on exterior siding to the left side of electric meter
---	------	--

Comments: