

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20241344  
Address: 840 NW BLUE PKWY, Unit:D, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                               | Inspector: | Outcome: | Date:                     |
|---|------------|----------|---------------------------|
| <b>Gas Piping Inspection - Commercial</b> | Robb Popp  | Partial  | Thursday, August 01, 2024 |

Corrective Action Required:

|   |      |  |
|---|------|--|
| 1 | Misc | Pressure test ok<br>-Paint all exterior metallic gas piping with corrosion resistant paint |
|---|------|--|

**Comments:**