

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241046

Address: 1427 SW WINTHROP TER, LEES SUMMIT, MO 64081
1425 SW WINTHROP TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Alex Fischer	Partial	Thursday, August 01, 2024

Corrective Action Required:

1	DCM5 ESC INSP DENIED	REQUESTED INSPECTION(S) DENIED DUE TO DEFICIENT EROSION CONTROL INSTALLATION.
---	-------------------------	--

-Silt fence at the front of the property has been damaged and is no longer effective. -Full erosion control measures must be maintained until CofO

Informational:

2	Misc	-Erosion control was in compliance at the time of the inspection
---	------	--

Comments: