

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20233582
Address: 3640 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Sediment Control (ESC) Inspection	Patrick Schonfeldt	Failed	Thursday, August 01, 2024

Corrective Action Required:

1	Misc	- provide silt fence erosion control at south side of lot along 150, clean mud from sidewalk on 150 side - clean mud buildup at gutter buddies - clean all mud and construction debris from Arboridge Dr including construction materials in center island
---	------	--

Comments: