

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20234497
Address: 2107 SW HARVEST MOON LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Thursday, August 01, 2024

Corrective Action Required:

1	Misc	-fireblock 1/2 bath hall wall to furr down ceiling space. -fireblock beam ends in basement -seal penetrations in n vertical to horizontal fireblocking
---	------	--

Comments: