

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20235207  
Address: 2931 SE SHENANDOAH PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Suspended Slab Inspection</b>	Khanh Nguyen	Failed	Thursday, August 01, 2024

Corrective Action Required:

1	Misc	Provide podium concrete slab reinforcement per plan
---	------	---

**Comments:**