

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241854
Address: 3820 SW RAVENGATE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Alex Fischer	Failed	Friday, August 02, 2024

Corrective Action Required:

1	Miscellaneous Correction	-Nail exterior garage sheeting to code along the top plate
---	--------------------------	--

This is a garage exterior portal inspection only

Partial Correction:

2	Miscellaneous Correction	Nail garage exterior sheeting to both top plates
---	--------------------------	--

Comments: