

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20242655
Address: 400 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	Robb Popp	Failed	Friday, August 02, 2024

Corrective Action Required:

1	Misc	Conduit to (8) light poles approved per letter and photos on permit **PROVIDE BORING REPORT FOR REMAINING (5) PIERS AT EAST PARKING LOT -(conduit at "diamonds" witnessed to be 14"-18" depth. Min 24" depth under driving surfaces is required)
---	------	---

Comments: