


NOTES:

1. Design based on LED Light Pole < 15 ft tall.
2. LED head shall not be > 3 ft from pole centerline
3. Conduit per Electrical Design
4. Concrete shall be 4000 psi Min.

CONCRETE LED LIGHT POLE BASE DETAIL

NOT TO SCALE


RC/ACA FOR REVIEW 7-31-24



405 S. Leonard St., Suite D
Liberty, Missouri 64068

816.781.4200 ■
fax 792.3666

www.agcengineers.com



SUMMIT ORCHARDS - SWIG
LEE'S SUMMIT, JACKSON COUNTY, MISSOURI

REVISED LED LIGHT POLE BASE