



**LEE'S SUMMIT**  
MISSOURI



---

**FIRE DEPARTMENT**

**Prevention Division**  
**(816)969-1300**

**PLANS REVIEW CONDITIONS**

Permit No: PRCOM20240778  
Project Title: MCC AUTOMOTIVE INSTITUTE -  
BUILDING ADDITION

Location:  
500 SW LONGVIEW RD, LEES SUMMIT, MO 64081

Type of Work:

Occupancy Group: S-1

Description: MCC AUTOMOTIVE INSTITUTE -  
BUILDING ADDITION AND RENOVATION OF EXISTING

Construction Type: Type IIB (Unprotected)

Map Page:

Date: August 05, 2024

Applicant:

SIEMENS INDUSTRY INC  
P O BOX 80600  
INDIANAPOLIS, IN 46280

Primary: (317) 596-3260 Ext: 2546

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

**Alarm Plan Review**

**Reviewed By: Jim Eden**

**Released for Construction**

3. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Call (816) 969-1300 to schedule testing.

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**