

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20233869
Address: 130 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pavement-Surface	John Jackson	Partial	Tuesday, August 06, 2024

Informational:
1 Misc

07/23/24 Tuesday (ICON)
Contractor began to put forms up for the newly extend parking lot.

08/06/24 Tuesday (ICON)
Contractor laid the 2" commercial surface coat comparable to type 2 APWWA . Tacking coat was used before surface was installed. Temperature of asphalt fell within acceptable range when was installed.

Comments: