

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20235015  
Address: 2119 SW HOOK FARM DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Failed	Tuesday, August 06, 2024

Corrective Action Required:

1 Misc

- pay all fees
- outlet under kitchen sink wired incorrectly
- open electrical in bathrooms
- remove smoke covers for testing
- all hardwired appliances to have lockout at breaker where not in clear sight or f panel
- all non GFCI outlets in unfinished spaces to be single receptacle and labeled or GFCI protected
- set screw installed and sheered off at water anti syphon device
- missing face plates on multiple switches and outlets

**Comments:**