

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20235554

Address: 816 NE ALGONQUIN ST, LEES SUMMIT, MO 64064818 NE ALGONQUIN ST, LEES SUMMIT, MO  
64064814 NE ALGONQUIN ST, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:            | Inspector:    | Outcome: | Date:                    |
|------------------------|---------------|----------|--------------------------|
| <b>Erosion Control</b> | Shawn Hoffman | Failed   | Tuesday, August 06, 2024 |

Corrective Action Required:

|   |                                       |  |
|---|---------------------------------------|--|
| 2 | DCM2 ESC<br>DEFICIENT<br>INSTALLATION | DEFICIENT EROSION CONTROL INSTALLATION. NO FURTHER INSPECTIONS<br>UNTIL ADEQUATE EROSION CONTROL PROVIDED.<br><br>_ PROVIDE EROSION CONTROL UNTIL SOD IS PLACED. |
|---|---------------------------------------|--|

**Comments:**