

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241971
Address: 3828 SW RAVENGATE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Alex Fischer	Failed	Tuesday, August 06, 2024

Informational:

1	Miscellaneous Correction	- Exterior garage sheeting passed and is okay to cover
---	--------------------------	--

This is a garage portal inspection only

Corrective Action Required:

3	Misc	-Missing fire blocking at top of garage chase -Missing LUS24 truss hangers at front of garage -Missing HHUS28-2 brackets above garage door -Missing hold down device at NE corner basement stairs -Seal gas line penetration on North side exterior
---	------	---

Comments: