

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20240118  
Address: 515 NW MOORE ST, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Water Line - Construction Inspection</b>	John Jackson	Partial	Tuesday, August 06, 2024

Informational:

1	Misc	<p>07/25/24 Thursday JMJ (SDI Brandon) Contractor worked on the installation of private water main 2/45 degree bends, installing 2" copper to 4" water main with a 2" by 4" reducer. Contractor will backfill excavation they responsible for today and yesterday.</p> <p>08/02/24 Friday JMJ (SDI Brandon) Contractor installed a fire hydrant, and powder chlorine was installed in 6" inch pipe. The LS Water Dept. made a two inch tap on 6" main, also meter set was dropped off at site.</p> <p>08/05/24 Monday JMJ (SDI Brandon) Contractor excavating for backflow vault.</p> <p>08/06/24 Tuesday JMJ (SDI Brandon) Contractor installed 3/4" cooper water main to Dog park as-per project plans.</p>
---	------	---

**Comments:**