

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240530
Address: 2528 NE WOODLAND OAK CIR, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Alex Fischer	Failed	Wednesday, August 07, 2024

Corrective Action Required:

1	Misc	-Tie down bolts in garage not in center 1/3 of base plate -Missing Simpson joist hanger U210-3 between kitchen and great room -Half wall at covered deck not installed southeast corner, verify whether or not this is still part of the plan -Unable to locate supply lines to jacuzzi tub in master suite bathroom -Seal all exterior wall penetrations
---	------	---

Comments: