

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20240001  
Address: 2604 NE WOODLAND OAK DR, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Alex Fischer	Failed	Wednesday, August 07, 2024

Corrective Action Required:

1	Misc	-Anchor bolts in garage are not in middle 1/3 of base plate -Address surface mounted electrical cables at upper southeast corner of garage -Missing fire blocking at top of chase in powder room off of garage -Vent hose at powder room not installed -Missing joist hanger at north east corner of kitchen pantry -Seal all exterior wall penetrations
---	------	---

Comments: