



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20113275, Building Permit - Commercial
Address: 691 NW BLUE PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Partial	Tuesday, September 27, 2011

Corrective Action Required

1	MISC	FLOOR SINK AT UTILITY RM: SEAL PERIMETER TO WALL TO PREVENT DETERIORATION OF GWB
---	------	----------------------------------------------------------------------------------

Corrective Action Required

2	MISC	PLASTER TRAP TO BE INSTALLED AT WORK AREA
---	------	-------------------------------------------

Corrective Action Required

3	MISC	RESOLVE FIRE DEPARTMENT ISSUES
---	------	--------------------------------

Comments: OK TO SET UP FOR BUSINESS. NO PATIENTS NOR PUBLIC PRIOR TO APPROVAL.