

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20240778
Address: 500 SW LONGVIEW RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Shawn Hoffman	Failed	Wednesday, August 07, 2024

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">- Provide welding cert for steel work- Removal of damper not in use- Close all electrical boxes throughout- Electrical panels and outlets incomplete- Open stand pipe- Provide temp wall to prevent access to paint booth area- Label exhaust fans and label in panel
---	------	---

Comments: