



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20114000, Building Permit - Commercial
Address: 910 NW BLUE PKWY, Unit:R, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Commercial	John Borns	Passed	Tuesday, September 27, 2011

Above Ceiling Inspection	John Borns	Partial	Tuesday, September 27, 2011
-------------------------------------	------------	---------	-----------------------------

Partial Correction
2 MISC

OK TO COVER WHEN READY ACT CEILING FRAMING +
ABOVE-CEILING SYSTEMS EXCEPT AT WATER HEATER AND AT
TRUSS JOIST BOTTOM CHORD BRACES

Corrective Action Required
3 MISC

TRUSS JOIST BOTTOM CHORD BRACES MUST BE WELDED TO
BAR JOISTS

**Comments: RELEASE ELECTRICAL SERVICE. PERMANENT ADDRESS LABEL TO BE
AFFIXED TO SERVICE METER BEFORE FINAL INSPECTION.**