

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20226232
Address: 120 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Robb Popp	Partial	Wednesday, August 07, 2024

Corrective Action Required:

1	FIRST FLOOR	-Shaft layer, 1st and 2nd layer at 2nd floor separation in AHU 1E-233 -Shaft layer and 1st and 2nd layer at mech chase outside of AHU 1E-233 **COMPLETE RATED SSEMBLY AT SOILS AND MECH ROOMS -Shaft layer at mechanical room duct penetration
---	-------------	---

Corrective Action Required:

2 SECOND FLOOR

Corrective Action Required:

3	THIRD FLOOR	-Shaft and 1st adn 2nd layer at 3E-303 -Screw pattern at 3E-322, 323, 365, 264, 263
---	-------------	--

Comments: