



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

Prevention Division
(816)969-1300

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20242210	Date:	August 07, 2024
Project Title:	30HOP STREETS OF WEST PRYOR -	Applicant:	
TENANT FINISH			
Location:		ALLIANCE FIRE PROTECTION LLC	
1020 NW PRYOR RD, Unit:G, LEES SUMMIT, MO 64081		130 W 9TH AVE STE 101	
Type of Work:		KANSAS CITY, MO 64116	
Occupancy Group:	A-2		
Description:	30HOP - NEW TENANT FINISH FOR	Primary: (913) 888-0647	
BAR AND RESTAURANT			
Construction Type:	Type VB (Unprotected)		
Map Page:			

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Craig Hill

Rejected

1. 2018 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. .A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.

Provide PE stamped plans.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.