



August 5, 2024

City of Lee's Summit, MO
ATTN: Daniel Fernandez, Project Manager
220 SE Green St.
Lee's Summit, MO 64063

RE: PRSUBD20242373: Discovery Park, Lot 9-12 – Sewer and Water Extension

Own, Inc. has received your comments dated August 2nd, 2024 and has the following responses:

Required Corrections:

Engineering Review	Sue Pyles, P.E.	Development Engineering Manager	Corrections
Water	(816) 969-1245	Sue.Pyles@cityofls.net	

1. Please include pipe length and material for Water Line B in Profile view.

OWN Response: Pipe length and material added to Water Line B profile view. See Sheet C403 – Water Plan & Profile – 4 for more detail.

2. Please review the estimate quantities and revise as needed: 8" PVC, 8" C900, 8" Gate Valve.

OWN Response: Estimate of quantities revised. See Sheet C101 – General Notes for more detail.

Sincerely,

A handwritten signature in blue ink that reads "Jeff Bartz".

Jeff Bartz, PE (OWN, Inc.)