

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20242194  
Address: 2111 SW HOOK FARM DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Thursday, August 08, 2024

Corrective Action Required:

1 Misc

- complete pfh nailing to design
- add stud pack under lvl above kitchen both sides
- seal penetration in return air joist space bed 4 for dwv
- seal penetration in fireblock bed 4 wall to ceiling
- fire block beam ends in basement
- address all over notched exter wall studs for anchor bolts

**Comments:**