

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241902
Address: 1704 SW BUCKTHORN ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------------|-----------|---------------------------|
| All Rough Inspection - Residential | Mitchell Schwarz | Not Ready | Thursday, August 08, 2024 |

Corrective Action Required:

| | | |
|---|------|---|
| 1 | Misc | -address broken truss C06-HAVE ENGINEER PROVIDE CORRECTION. 8/8/24 not fixed to engineer specifications |
|---|------|---|

Comments: