

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20233582
Address: 3640 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|-----------------|------------------|---------------------------|
| Occupancy Inspection - Planning | Shannon McGuire | Temporary C of O | Thursday, August 08, 2024 |

Corrective Action Required:

1

The parking lot lighting was not installed at the time of my inspection. Please install these per the approved plans.

Corrective Action Required:

2

Along the north property line (adjacent to the church driveway) there was a tree that was installed and appears to not have survived the transplanting processes. This is a required tree per the approved FDP landscaping plan. Please replace the tree with one that has not died.

Comments: