

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20233582  
Address: 3640 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Pavement-Aggregate Base</b>	Patrick Schonfeldt	Passed	Friday, August 09, 2024

Informational:

1 Misc

6-4-24 PS contractor installing geo grid on compacted subgrade, grid has appropriate lap between rolls P.M. geo grid installed through parking lot

6-5-24 PS Base aggregate placed and compacted through parking lot

6-19-24 PS contractor installed geo grid, placed aggregate and compacting at approach and road connecting to parking lot

**Comments:**