

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20233582
Address: 3640 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Mitchell Schwarz	Failed	Friday, August 09, 2024

Corrective Action Required:

1	Misc	OKAY DELIVERIES AND PERMANENT FIXTURES
		<ul style="list-style-type: none">-complete painting of gas line-outlets required in 25' of RTU-label all RTU's and fans-label hallways doors for electrical panels-GFCI protection for outlet near sink in SW most room-provide permanent address as discussed on site-address pending pier inspection-upload engineer report for trash enclosure footing-address all outstanding items from other department

Comments: