

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20236052

Address: 3712 SW MARYVILLE PL, LEES SUMMIT, MO 640823716 SW MARYVILLE PL, LEES SUMMIT, MO  
640823718 SW MARYVILLE PL, LEES SUMMIT, MO 640823710 SW MARYVILLE PL, LEES  
SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Plot Plan Inspection</b>	Kyle Beard	Failed	Monday, August 12, 2024

Corrective Action Required:

2	Miscellaneous	-Water meters in 3716 and 3712 appears to be below grade.
	Correction	-Water meter for 3718 is covered
		-Water valves in lot 3710 are about 24 inches above grade

**Comments:**