

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20226232
Address: 120 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Failed	Monday, August 12, 2024

Corrective Action Required:

1	Misc	Partial occupancy for ASC Expansion at 1st floor: -Submit final 3rd party inspection report -Complete fire rated assemblies at AHU and Soils room -Complete corrections for all other departments -Install all exterior lighting at North exit -Submit phasing and Egress plans to City PM for review by all departments
---	------	---

****OK TO STOCK AND FURNISH**

Comments: