

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20226232
Address: 120 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Robb Popp	Partial	Monday, August 12, 2024

Corrective Action Required:

1 FIRST FLOOR

*****AREAS APPROVED TO COVER:

Complete except as noted:

*AHU

-Address duct penetration/ complete firewall

Corrective Action Required:

2 SECOND FLOOR

Above-ceiling OK below:

-Soffits in waiting room area and adjacent corridors

**Complete except as noted below:

-Team Center 2E-330, Staff Lounge 2E-232, Staff TLT 2E-231A, Elevator Lobby

Corrective Action Required:

3 THIRD FLOOR

*****AREAS APPROVED TO COVER:

Soffits at 3E-355, 346, 338

Comments: